



CHABOT- LAS POSITAS COMMUNITY COLLEGE DISTRICT

Purchasing and Warehouse Services Department

August 20, 2007

Addendum No. 3

INVITATION FOR BID No. 08-01 Athletic Facilities Renovation, Chabot College

All Prospective Bidders:

This Addendum modifies the original Bid Documents for the above Bid. Acknowledge receipt of this addendum in the space provided on the **SIGNATURE FORM**. Failure to do so may subject Bidder to disqualification.

The original Bid Documents are modified by the additional information as follows:

Item No.	Location in Contract Documents, Specifications and Drawings	Description
1	Ford Graphics Website	To correct, the website address is www.fordgraphics.com . The addendum and all attachments are available in the public plan room section of Plan Well under Chabot CC, Bid No. 08-01, including the eleven full size drawings for increment two identified in addendum #2, item #1, as well the three reissued full size drawings identified in addendum #2, item #7. All original drawings and additional drawings can be found under Bid No. 08-01 in the <u>Most Current Set and Issues</u> .
2	Specification Section 04220, and Addendum #2, Item #25	The shrinkage for the block to 0.065% per ASTM C90 is acceptable, provided that expansion joints are at not more than 25' O.C. Anything more than 25' and DSA will require field tests.
3	Specification Section 09300	In Part 2-Products, 2.01 Materials, Paragraph B.1 we have changed "Toilet Room Wall Tile" to "Toilet Room Wall and Floor Tile", as this specification also applies to the floor tiling.

All other terms and conditions of BID No. 08-01 to remain the same.

END OF ADDENDUM No. 3