



State of California
DEPARTMENT OF GENERAL SERVICES
 DIVISION OF THE STATE ARCHITECT
 1515 Clay Street, Suite 1201 • Oakland • California 94612
 Phone (510) 622-3101 • Fax (510) 622-3140

www.dsa.dgs.ca.gov

JChan

**Addendum, Change Order,
 Drawing, Deferred Approval
 Worksheet and Transmittal Memo**


New **Resubmittal** **Date Sent:** 2/6/09 **File #** 1-13 **Appl. #** 01-109151

Job **Chabot College Buildings 300 and 500**

Addendum Number 3	Deferred Submittal	Preliminary Change Order	Change Order Number	Other
-----------------------------	---------------------------	---------------------------------	----------------------------	--------------

List of Material Received:	A. Master Copy 3			
	B. Copies			
	C. Tracing(s) each	of Sheets(s) Numbers(s)		
	D. Prints(s) each	of Sheets(s) Numbers(s)		
	E.			
	F.			

RECEIVED
 FEB 09 2009



List of Material Approved:

List of Material
 To: Architect Structural Engineer
 Name: **HMC ARCHITECTS**
 Address: 1570 The Alameda, Suite 330
 San Jose, CA 95126
 Item
 Copies **TWO (2)**

To	From
Co.	No. of Pages
Fax No.	Phone No.

kj 2/10/2009


Remaining Requirements:
 None Corrections Required Change Order Required
 If Corrections are required, please submit the following:
 1) Intact marked up check set.
 2) This transmittal memo.
 3) Two corrected copies of submittal.
 4) Calculations and other back-up information.
 5) Drawings bearing preliminary approval stamps to avoid re-review whenever possible.

Remarks:

Notes for Clerical Use:
 Please make file copy of: transmittal Other:
 Extend Plans and specs approval to cover:
 Revised Plans and Specs.
 Additional: Plans and Specs. Scope increase:
 Type of Approval: Scan and keep one (1) copy

Checked by	ACS <input checked="" type="checkbox"/> Not Required	FLS <input checked="" type="checkbox"/> Not Required	SSS <input type="checkbox"/> Not Required <i>J.Chan</i>
Approved by			<i>JChan</i>
Date			<i>2/9/09</i>

HMC ARCHITECTS
1570 The Alameda, Suite 330
San Jose, California 95126



January 30, 2009

Chabot College Modernization
of Buildings 300 and 500
Chabot-Las Positas Community College District
HMC # 3342002, DSA #01-109151

APPROVED
DIV. OF THE STATE ARCHITECT

AC F/LS SS *JChan*
APPL. NO. 01-109151 DATE 2/9/09

ADDENDUM NO. 3

The following changes, additions, deletions or corrections shall become a part of the Contract Documents for the project named above and all other conditions shall remain the same. The bidders shall be responsible for transmitting this information to all affected subcontractors and suppliers prior to the closing of bids.

GENERAL NOTES

Item No. AD-3.1: Security systems

- A. The security system server is located in Building 300. Contractor shall coordinate access with the Owner. The security system for the entire Campus has to remain operational during programming. At the completion of programming, contractor shall make sure that security system throughout Campus is fully operational. Contractor shall be responsible for any costs associated with these requirements.

SPECIFICATIONS

Item No. AD-3.2: Reference Section 1200, Project Meetings

- A. Revise Subparagraph 1.04.A.3 to read as follows:
 "3. The Construction Manager will preside at meeting"

Item No. AD-3.3: Reference Section 11 52 13, Projection Screens

- A. All projection screens to be OFCI. The aspect ratio for the throw distance indicated in plans shall be 4 : 3.

Item No. AD-3.4: Reference Section 28 16 00, Intrusion Alarm System

- A. Remove section 28 16 00 Intrusion Alarm System included in addendum 2, item AD-2.1, and use section 28 10 00 Electrical Access Control and Intrusion Detection per original DSA approved project manual.

DRAWINGS

Item No. AD-3.5:

Reference Drawing AD1-E5

- A. Revise Note # 19 to read as follows:

“PROVIDE ESSEX MODEL KTP-162-SN MULLION MOUNT 8-BIT WORD KEYPAD AND AMAG S830-CG MULLION MOUNT CARD READER. WIM-4 TO BE INSTALLED IN AMAG CABINET IF A 4DBC BOARD IS BEING USED OR WIM-8 TO BE INSTALLED IN AMAG CABINET IF A 8DBC BOARD IS BEING USED TO SERVE AS AN INTERFACE BETWEEN THE KEYPAD AND THE CONTROLLER.”

HMC ARCHITECTS

Lee Salin, AIA